

Section VII. Technical Specifications

Bidders must state “**Comply**” in the column “**Statement of Compliance**” against each of the individual parameters of each “Specifications.”

| Colocation of PCO Server for the Service Continuity Project (Procurement/ Contract No. 2024-10-220-2) | | | |
|---|---|-------|-------------------------|
| Item | Description | Qty | Statement of Compliance |
| | Facility Specifications <ul style="list-style-type: none"> Security: Access control and CCTV surveillance | 1 Lot | |
| | Network Connectivity <ul style="list-style-type: none"> Bandwidth: At least 50 Mbps bandwidth. Latency: Low-latency network connectivity with guaranteed bandwidth. | | |
| | Rack Space <ul style="list-style-type: none"> Size: 42U standard rack. Network Ports: At least two gigabit network ports per rack, expandable. Rack Access: 24/7 access to the rack for authorized personnel. | | |
| | Power <ul style="list-style-type: none"> Power Backup: UPS for continuous power delivery | | |
| | Location: <ul style="list-style-type: none"> Outside NCR (Preferably in Region 1 and III) | | |
| | Contract: (1 Year contract) | | |

Conforme:

Full Name and Signature of
Bidder/Authorized Rep :

Designation :

Name of Company :